

**TAMIL NADU FIRE AND RESCUE SERVICE DEPARTMENT**  
**NO OBJECTION CERTIFICATE**

R.C.NO : 284/V/2022  
LICENSE NO : 19/2022  
DATE : 04.07.2022

FIRE AND RESCUE STATION  
ASHOK NAGAR, CHENNAI-83.

**Subject :** Fire and Rescue Services Department – Ashok Nagar Fire and Rescue Station for purpose of no objection certificate – REG.

**Ref :** 1. G.O. No. 117 School Education (2) Dept. Date: 07.09.2004.  
2. G.O. No. 122 School Education (2) Dept. Date:14.09.2004.  
3. G.O. No. 123 School Education (2) Dept. Date:14.09.2004.  
4. The Requisition letter from The Principal , CHHATHRAPATHY SHIVAJI D.A.V SECONDARY SCHOOL 29.06.2022.

\*\*\*\*\*

Based on the Govt. order mentioned above and the requisition letter given by the M/S. CHHATHRAPATHY SHIVAJI DAV SECONDARY SCHOOL at No. 29, CIRCULAR ROAD, UNITED INDIA COLONY, KODAMBAKKAM, CHENNAI – 600 024. Tamil Nadu the buildings and premises comprises of GROUND + TWO FLOORS EACH Owned / occupied M/S. CHHATHRAPATHY SHIVAJI DAV SECONDARY SCHOOL have complied with the fire prevention and fire safety requirements in accordance with rule of State Fire Service Rules and verified on 02.07.2022 in the presence of Principal and that the school is granted NOC for a period of one year from 04.07.2022 to 03.07.2023 subject to the conditions stated below.

THE ABOVE PREMISES INSPECTED BY STATION OFFICER  
FIRE AND RESCUE STATION. S.RAMESH ON 02.07.2022.

**CONDITIONS**

1. The License is valid for ONE YEAR month from the date of issue.
2. Fire Safety Systems should be maintained in good working condition.
3. Mock drill to be conducted periodically with the help of local fire brigade.
4. Any erection of permanent or temporary structure should be intimated to the department.
5. A trained Fire Service Persons preferably retired one should be appointed.
6. Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are insisted.



- a) Building occupancy capacity should not be more than 4 people per Sq. meter as per the National Building Code-2005.
  - b) The staircase treads and flooring shall be treated with rough finish (grooving) to avoid falling of children.
  - c) As per Para 6.3 of the BIS Standards IS 14435:1997 as the class rooms have only one entrance, the capacity of the class rooms shall have to be limited to 45 Students.
  - d) Periodical maintenance and care should be taken to maintain all fire protection equipments.
  - e) Mock drill has to be conducted at regular intervals in consultation with the District Office, Fire and Rescue Services, Chennai South District, at Ashok Nagar.
  - f) The class rooms should always be in the ground floor up to 3<sup>rd</sup> Students.
  - g) The class room doors / windows should be made of either non-combustible materials with high fire-resistance rating.
  - h) The class room doors / windows shall always open outwards.
  - i) The class room doors / windows shutters when opened should not obstruct movement along the exit or escape route.
  - j) A class room shall have two entrances. One door with opening towards the teachers end and the other door on the other end of the class room with only a simple latch / tower bolt arrangement for locking from inside. This door shall not have any arrangement for locking from outside.
  - k) The school shall have proper Evacuation of plan of action to rescue the children during any emergency in the school premises.
- If there is any violation and deviation from the Govt. Rule and Act the License issued will stand cancelled.



நிலைய அலுவலர்  
தீயணைப்பு (ந) மீட்டிங் பணிகளை தலைவம்  
அசோக் நகர், சென்னை - 600 083

To : M/S. CHHATHRAPATHY SHIVAJI DAV SECONDARY SCHOOL,  
No. 29, CIRCULAR ROAD, UNITED INDIA COLONY,  
KODAMBAKKAM, CHENNAI - 600 024.

CC : DISTRICT OFFICER, CHENNAI SOUTH DISTRICT.

